WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31019
Permit No. 45902
Basin 170

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4207

1. OWNER Dirk Agee
MAILING ADDRESS Rachel, Nevada
ADDRESS AT WELL LOCATION Rachel, Nev

2. LOCATION SW ¼ NW ¼ Sec. 34 T. 3 So. N/S R. 55 E. Lincoln County
PERMIT NO. 45902 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☒

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	4
gravel		4	20	16
sand in gravel		20	62	42
gravel		62	75	13
sand in gravel		75	120	45
gravel some boulders		120	155	35
clay Red		155	165	10

[illegible] This [illegible] not [illegible] This Driller was called to [illegible] the [illegible] was going to [illegible] information in distribution that we have received.

RECEIVED
DEC 2 7 1988
Div. of Water Resources
Branch Office - Las Vegas, Nv.

Date started April 19, 19 88
Date completed May 4, 19 88

7. The well test was not completed by us.

WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 14"x50', WELL CONSTRUCTION
Diameter hole 10x115' inches Total depth 165 feet
Casing record
Weight per foot ..... Thickness 3/8"

Diameter	From	To
10" inches	0 feet	165 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 155 feet

Perforations:
Type perforation Torch
Size perforation ¼ x 12
From 85' feet to 155' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 85' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Darell H. Free (Contractor)
Address Box 122 Panaca, Nv 89042 (Contractor)
Nevada contractor's license number 3422
Nevada contractor's drillers number 30
Nevada driller's license number 455 (Actual Driller)
Signed Darell H Free (Contractor)
Date May 3, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434