WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. B1031
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4060

1. OWNER U.S. Ecology Inc.
MAILING ADDRESS P.O. Box 578 Beatty Nev 89003
ADDRESS AT WELL LOCATION SAME

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 13S N/S R. 47 E. NYE County
PERMIT NO. Under Waiver 312 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitoring
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand + Gravel		0	14	14
Sand + Gravel, Trac Silt		14	170	156
Sand Gravel, Trac Clay		170	280	110
Fine Sand + Gravel		280	285	5
Fine Sand + Gravel	285		306	21

RECEIVED SEP 2 1988 Div. of Water Resources Beatty Office - Nevada, NV

Date started Aug 4, 1988
Date completed Aug 16, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 306 feet
..... inches
..... inches
Casing record Mild Steel + Stainless Steel
Weight per foot 22 Thickness .250

Diameter	From	To	
6" inches	2.5' Above Ground feet	234.4 feet	Bl. Pipe
6" inches	234.4 feet	274.4 feet	S.S. Pipe
6" inches	296 feet	301 feet	S.S. Pipe
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 273.9 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 273.9 feet to 298 feet

Perforations:
Type perforation Stainless Screen ~~[illegible]~~
Size perforation ~~[illegible]~~ .40"
From 276.4 feet to 296.4 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 284.4 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address Rt 15 Box 543 Amargosa Valley Nev 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376A
Nevada contractor's driller's number issued by the Division of Water Resources C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Rau (By driller performing actual drilling on site or contractor)
Date Sept 15 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627