WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31033
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5798

1. OWNER US Ecology Inc
MAILING ADDRESS PO Box 578 Beatty Nev. 89003
ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 135 N/S R. 47 E. Nye County
PERMIT NO. Under Waiver 315 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE Monitoring: Domestic ☐ Irrigation ☐ Test ☑ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand & Gravel		0	21	21
Sand + Gravel with Some Cementation		21	109	88
Fine Sand Gravel Silt		109	298	189
Fine Sand Gravel & Clay		298	306	8
Find Sand + Gravel	306		326	20

RECEIVED 1988

Date started Oct 3, 1988
Date completed Oct 16, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼" inches Total depth 326.6 feet
inches
inches
Casing record Mild Steel + Stainless Steel
Weight per foot 22.65 Thickness .250

Diameter	From (Ground)	To	
6 inches	25[illegible] feet	258.5 feet	Mild
6 inches	258.5 feet	300.6 feet	Stainless
6 inches	320.6 feet	325.6 feet	Stainless
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 298 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 298 feet to 321 feet

Perforations:
Type perforation Stainless Steel Screen
Size perforation .40"
From 300.6 feet to 320.6 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 305.6 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address RT 15 Box 543 Amargosa Valley 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada contractor's driller's number issued by the Division of Water Resources C 23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 17 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627