



WELL DRILLER'S REPORT
 Please complete this form in its entirety

NOTICE OF INTENT NO. 5077

PRINT OR TYPE ONLY

1. OWNER Jim & Kay King ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 710 HCR 31 2670 W COPPER
JEAN, NEV. 89019 SANDY VALLEY NEV.
 2. LOCATION SE 1/4 SW 1/4 Sec. 15 T. 2A N/S R. 15.6 E CLARK County
 PERMIT NO. 580-100-031 Parcel No. _____ Subdivision Name BOOK # 1577 DC # 1536115
 Issued by Water Resources _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & ROCK		0	12	12
CEMENTED ROCK		12	41	29
SANDY CLAY		41	49	8
CEMENTED ROCK		49	54	5
CONS SANDY CLAY		54	58	4
WHITE CLAY		58	71	13
BROWN CLAY		71	76	5
CORAL		76	92	16
LOOSE ROCK	WTR	92	94	2
BROWN CLAY		94	99	5
CONS CLAY		99	106	7
HARD BAN CLAY		106	118	12
SANDSTONE		118	120	2
SAND & ROCK	WTR	120	125	5

8. WELL CONSTRUCTION
 Diameter 14 inches Total depth 125 feet
 _____ inches
 _____ inches
 Casing record STEEL
 Weight per foot 12.5 Thickness 1.56

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>125</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 125 feet
 Perforations:
 Type perforation FLAME CUT
 Size perforation 3/8 X 4" ARROWS @ 16" center
 From 90 feet to 125 feet
 From _____ feet to _____ feet

RECEIVED
 SEP 23 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started SEPT 6 1988
 Date completed SEPT 16 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 30 Draw down 0 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 83 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 69 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RCBB INC Contractor
 Address 1701 W CHSTN BLVD LAS VEGAS 89102 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 020301
 Nevada contractor's driller's number issued by the Division of Water Resources 1352
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
 Signed Robert Spurluck
 By driller performing actual drilling on site or contractor
 Date Sept 20- 88

