WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31098
Permit No. 12008
Basin

1. OWNER Karl Stanley Brown ADDRESS 3500 Callahan, Las Vegas, Nev

Replacement

2. LOCATION SE ¼ NW ¼ Sec. 31 T. 21 N/S R. 62 E. Clark County
PERMIT NO. Part of SW NW SE NW 31 21 62 12008

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy soil		0	3	3
white clay		3	20	17
brown clay		20	29	9
brown sandy clay	x	29	35	6
brown clay		35	60	25
gravel		60	70	10
clay		70	87	17
gravel	xx	87	95	8
graveley clay		95	115	20
brown clay		115	135	20
graveley clay	xx	135	165	30
brown graveley clay	xxx	165	195	30
graveley clay		195	205	10
brown clay		205	210	5
gravel		210	215	5
brown sticky clay		215	235	20
gravel	xxx	235	237	2
brown sticky clay		237	241	4
gravel	xxx	241	248	7
brown clay		248	250	2

RECEIVED
JUL 07 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-28-88, 19
Date completed 5-9-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed	50 G.P.M.	from 75 ft.	

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 250 feet
Casing record 8 5/8 to 250 ft
Weight per foot .156 Wall Thickness

Diameter	From	To
12" Hole inches	0 feet	80 feet
10" Hole inches	80 feet	250 feet
inches	feet	feet
8 5/8 inch casing inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 80 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Torch cut
Size perforation 3/16" X 10"
From 130 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 19 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name S. R. McKinney & Sons, Inc.
Address 1042 South Main St. Las Vegas, Nevada
Nevada contractor's license number 2065
Nevada driller's license number 45
Signed [signature]
Date 6-30-88

USE ADDITIONAL SHEETS IF NECESSARY

5471