


OFFICE USE ONLY  
 Log No. 31122  
 Permit No. \_\_\_\_\_  
 Basin 212



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5190

PRINT OR TYPE ONLY

1. OWNER PALM MORTUARY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 12 T. 22S N/S R. 61 E. CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SANDY CLAY		0	41	41
CALICHE		41	50	9
GRAVEL	X	50	62	12
RED SANDY CLAY		62	140	78
RED CLAY, GRAVEL		140	200	60
RED SAND, GRAVEL		200	244	44
CEMENTED GRAVEL	X	244	260	16
GREEN CLAY		260	285	25
CEMENTED GRAVEL &	XX	285	450	165

8. WELL CONSTRUCTION  
 Diameter 14 inches Total depth \_\_\_\_\_ feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 10  
 Weight per foot 21.15 Thickness 188  

Diameter	From	To
<u>24</u> inches	<u>0</u> feet	<u>50</u> feet
<u>10</u> inches	<u>50</u> feet	<u>450</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 0 feet to 450 feet  
 Perforations:  
 Type perforation TORCH  
 Size perforation 1/16 X 6" X 4 AROUND  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
AUG 22 1988  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV


Date started APRIL 11 1988  
 Date completed APRIL 25 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>125</u>	<u>?</u>	<u>8</u>

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature W °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED B. ALLEN III Contractor  
 Address 4847 S. VALLEY VIEW BLVD Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 018917  
 Nevada contractor's driller's number issued by the Division of Water Resources 1301  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1376  
 Signed Fred B. Allen III  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_



BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours