

OFFICE USE ONLY
 Log No. 31146
 Permit No. 47609
 Basin 105-Carson V
 9304

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9304

PRINT OR TYPE ONLY

1. OWNER Bentley Nevada Corp. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 157 Buckeye & Orchard Rd
Minden Nev. 89423
 2. LOCATION N1/2 1/4 SW 1/4 Sec. 27 T. 13 N/R. 20 E. Douglas County
 PERMIT NO. 47609 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fine sand trace of clay		0	20	20
hard sand		20	40	
clay some gravel		40	90	
sand & gravel		90	160	
clay		160	205	
sand & gravel		205	215	
clay sandy		215	235	
sand		235	245	
clay		245	250	
sand & gravel		250	265	
clay		265	300	
sand		300	315	
clay		315	355	
sand		355	365	
clay		365	420	
sand & gravel		420	510	

8. WELL CONSTRUCTION

Diameter 12" inches Total depth 510 feet
 Borehole 24" inches ~ 50'
18" inches ~ 510'
 Casing record _____
 Weight per foot _____ Thickness 250

Diameter	From	To
<u>20</u> inches	0	feet
<u>12</u> inches	<u>2</u>	feet
_____ inches	_____	feet

 Surface seal: Yes No Type Cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 4 feet to 510 feet
 Perforations:
 Type perforation well screens
 Size perforation sharp wire 100 slot Johnson
 From 110 feet to 120 feet
 From 250 feet to 270 feet
 From 310 feet to 330 feet
 From 430 feet to 510 feet

Date started Aug 19 1988
 Date completed Oct 12 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>336</u>	<u>8</u>	<u>2</u>	
<u>585</u>	<u>17</u>	<u>2</u>	
<u>1253</u>	<u>40</u>	<u>2</u>	

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. None Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 34.5 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 64 °F Quality UK

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DASIS DRILLING INC.
 Address P.O. Box 21421 Carson City NV
 Nevada contractor's license number 0023129
 issued by the State Contractor's Board
 Nevada contractor's driller's number _____
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Amel
 By driller performing actual drilling on site or contractor
 Date Nov. 10, 1988