

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 11937

PRINT OR TYPE ONLY

1. OWNER Donald & Susan Berry ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 1650 Collins 395 Descanso  
Reno, Nv 89506

2. LOCATION NW 1/4 NW 1/4 Sec 12 T 21 N/S R 20 E Washoe County \_\_\_\_\_  
PERMIT NO. 76-290-16 Spanish Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green white yellow				
D.G. with brown green white granite boulders		0	15	15
Blue green granite broken & fractured	265 284	15	296	281
T.D. 296'				

FEB 17 AM 10:00 '89

STATE ENGINEER

8. 10"- 53' WELL CONSTRUCTION  
Diameter 6 5/8 inches Total depth 296 feet  
Casing record 6 5/8 inches  
Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>296</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
Depth of seal 75 feet  
Gravel packed: Yes  No   
Gravel packed from 75 feet to 256 feet

Perforations:  
Type perforation factory  
Size perforation 3/32 X 3  
From 256 feet to 276 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/5/89, 19\_\_\_\_\_  
Date completed 1/12/89, 19\_\_\_\_\_  
Date completed \_\_\_\_\_, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 150 feet below land surface  
Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service, Inc.  
Contractor  
Address 625 Spice Islands Dr Suite L Sparks, Nv  
Contractor 89431

Nevada contractor's license number 15291  
issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
issued by the Division of Water Resources

Nevada driller's license number issued by the 1511  
Division of Water Resources, the on-site driller

Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
Date 1/16/89