

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9219

1. OWNER LOUI BURGARELLO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 50 Snider Way 7870 Kinney Lane
Sparks, NV 89431 Reno, NV 89511
 2. LOCATION SE 1/4 NE 1/4 Sec. 2 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. 41-251-04 SW Reno
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay w/some gravels & sands		0	11	11
Soft sandy brown clay		11	16	5
Brown clay		16	34	18
Boulders		34	36	2
Sandy brown clay		36	45	9
Soft zone		45	47	2
2Brown sandy clay		47	55	8
Soft zone		55	56	1
Brown sandy clay		56	91	35
Soft zone		91	93	2
Brown sandy clay		93	102	9
Sand & gravel	X	102	104	2
Sandy clay		104	105	1
Soft brown clay		105	109	4
Brown sandy clay		109	110	1
Coarse sands	X	110	115	5
Brown saandy clay with volcanic boulders		115	159	44
Soft zone		159	161	2
Brown sandy clay with volcaanic boulders		161	170	9
Brown vulcanic rock		170	204	34
Fracture zone	X	204	207	3
Brown vulcanic rock		207	218	11
Fracture zone	X	218	222	4
Brown vulcanic rock		222	230	8

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 230 feet

Casing record 230' steel casing installed.

Weight per foot _____ Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>230</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 230 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 104 feet to 164 feet
 From 184 feet to 224 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 1-19-89, 19____
 Date completed 1-26-89, 19____

7. WELL TEST DATA

Pump RPM	A.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 0 artesian feet below land surface

Flow 100+ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor
 Address P.O. box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada contractor's driller's number issued by the Division of Water Resources 908

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling, Inc.
 Date January 31, 1989