WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31210
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12476

1. OWNER Ray Parodi
MAILING ADDRESS 1396 B Kimmerling Gardnerville, Nevada
ADDRESS AT WELL LOCATION 1068 Log Cabin Gardnerville, Nevada

2. LOCATION NE ¼ SE ¼ Sec 23 12 T 12 N S R 20 E Douglas County
PERMIT NO. (23-234-05) Sagewood Estates
Issued by Water Resources — Parcel No. — Subdivision Name
new apn # 1220-12-710-22

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Cobbles and small gravels with clay		4	171	169
Hard Cemented gravels		171	228	57
Gravels with fine sand lenses Gravels Carrying water		228	255	27
T.D. 255'				

'89 MAR -2 AM 10:00 ENGINEERS OFFICE

23-234-050
1068 Log Cabin Rd
1071 Center Ln
Legal is
NE SE Sec 12
12N 20E
New APN
1220-12-710-22

Date started Feb 23, 1959
Date completed Feb 27, 1959

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well by flushing with clean water, gravel packed while flushing. Blew with air for 2 hours to clean well			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60' inches Total depth 255 feet
9 3/4 inches
inches
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	255 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 255 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 230 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 190 feet below land surface
Flow 20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A G H Pump Co
Contractor
Address 5321 Hiway 50 E #3 Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature]
By driller performing actual drilling on site or contractor
Date Feb 28, 1959

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627