WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31211
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12438

1. OWNER Clyde Wallis Rogney + Gains Const + Develop
MAILING ADDRESS P.O. BOX 229 GENOA, NEVADA 89411
ADDRESS AT WELL LOCATION 1819 Sullivan Drive Gardnerville, Nevada

2. LOCATION SW ¼ NW ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. None (Issued by Water Resources) | 29-490-02 (Parcel No.) | Ruchenstroth Flat Area (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Boulders, Sand		6	85	79
Clay interspersed with Medium pea gravels		85	210	125
Pea gravel, Sand with water	✓	210	240	30
T.D. 240 Ft				

MAR 15 A10 04
STATE ENGINEERS OFFICE

Date started March 3, 1989
Date completed March 8, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well with Clear water to Remove drill mud & gravel pack. Developed well with 250 psi air. Blew 20+ GPM from 210' for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60' inches Total depth 240 feet
9 3/4 inches
inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 240 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 215 feet to 235 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 210 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H PUMP Co. Contractor
Address 5551 Hiway 50 E #3 Carson City, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/7/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627