[illegible]ISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31212
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12437

1. OWNER Raymond Andres
MAILING ADDRESS Minden, Nevada
ADDRESS AT WELL LOCATION 1307 Jacobson Lane Gardnerville, Nevada

2. LOCATION SE ¼ NW ¼ Sec. 4 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. None (Issued by Water Resources) 35-150-32 (Parcel No.) parcel map (Subdivision Name) No Subdivision

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	8	8
Brown Clay with Small Gravels		9	57	49
Fine Gravels with Sand		57	82	25
Clay Seam		82	86	4
Fine to Course Gravel, to 3/4" with water	✓	86	120	34
T.D. 120 Ft				

'89 MAR -2 A10:11
STATE ENGINEERS OFFICE

Date started Feb 21, 1989
Date completed Feb 22, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well removed with air. Gravel packed well. Blew 30+ GPM from 110' for 2 hours to clean			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 120 feet
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 35 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H pump Co. (Contractor)
Address 555 Hiway 50 E #3 Carson City, NV 89701 (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 (Actual Driller)
Signed Quinton Butts (Contractor)
Date Feb 23, 1989

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-88) O-627 CR434