WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 31228
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 1904

1. OWNER Steve Cote Const (Clemons)
MAILING ADDRESS Carson City, NEVADA
ADDRESS AT WELL LOCATION 32 BELLVUE RD Carson City, NEVADA

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 16 N/S R. 19 E W/Shoe County
PERMIT NO. ~~W-Cty-003460~~ (Issued by Water Resources) 55-168-11 (Parcel No.) LATHROP RANCH ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ RMD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, Sandy loam Groundwater at 4 feet	✓	0	7	7
Sand, iron, pyrite fine to course	✓	7	81	74
Course granodiorite heavy with pyrite	✓	74	124	50
Granodiorite, hard		124	127	3
Granodiorite, hard, fractured with clean water	✓	127	150	23
T.D. 150 Ft				

Date started March 21 1989
Date completed March 1989

RECEIVED
STATE ENGINEERS OFFICE
MAR 30 1989
09:04 AM

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove mud & to gravel pack. Developed well with air for 2 hours Blowing 25+ GPM from 110'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" to 80' inches Total depth 150 feet
Casing record Steel 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 150 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 9/32 x 3"
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 30 feet below land surface
Flow 25+ G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AEH pump Co (Contractor)
Address Carson City, Nevada (Contractor)
Nevada contractor's license number 23895
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Clinton Butts (Actual Driller)
Date March 24, 1989 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434