

OFFICE USE ONLY  
 Log No. 31237  
 Permit No. \_\_\_\_\_  
 Basin 6-21

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

*OF DAB*  
 RICHARD LUHRING

NOTICE OF INTENT NO. 12498

1. OWNER RICHARD LUHRING ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 915 Vine Street 115 River Dale Crt.  
Reno, NV 89503 Verdi, NV 89439  
 2. LOCATION NE 1/4 SE 1/4 Sec 7 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. 38-291-22 River Dale Subdv. Verdi lot 2 blk E  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Smaller boulders, sand gravel cemented with brown clay		0	31	31
Brown clay		31	38	7
Gray clay		38	66	28
Soft zone (NO WATER)		66	68	2
Gray clay		68	163	95
Soft zone (app 3 GPM)	X	163	170	7
Gray clay		170	192	22
Soft zone	X	192	202	10
Gray shell rock		202	255	53
Fracture	X	255	265	10
Gray shell rock		265	275	10

*Deepened by log 49577*

'89 MAR 14 A 9:25  
 STATE ENGINEER

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 275 feet

Casing record 275' steel casing installed.

Weight per foot \_\_\_\_\_ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement grout

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from 50 feet to 275 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3 x 6 around

From	To
<u>180</u> feet	<u>207</u> feet
<u>247</u> feet	<u>267</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 2-28-89, 19\_\_\_\_  
 Date completed 3-1-89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 630 feet below land surface

Flow 15 G.P.M. \_\_\_\_\_ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor

Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number 22549  
 issued by the State Contractor's Board

Nevada contractor's driller's number 908  
 issued by the Division of Water Resources

Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller

Signed Wayne Drilling, Inc.  
 By driller performing actual drilling on site or contractor

Date March 6, 1989