

OFFICE USE ONLY  
 Log No. 31214  
 Permit No. V-04776  
 Basin. 13-207

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11731

1. OWNER White Pine County School District ADDRESS AT WELL LOCATION Land Grady School  
 MAILING ADDRESS P.O. Box 400 ELY NV 89301 P.O. Box 29 Land NV 89317

2. LOCATION SW 1/4 NE 1/4 Sec 33 T 12 N/S R. 62 E White Pine County  
 PERMIT NO. 04776 Lot 6 Check 6 Land townsite survey  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	5	5'
CLAY cobbles		5	10	5
gravel clay conglomerate		10	15	5
Sandy clay		15	20	5
gravel clay con.	water	20	25	5
Sandy clay		25	39	14
gravel	water	39	40	1
Sandy clay		40	43	3
gravel	water	43	45	2
Sandy clay		45	55	5
gravel	water	55	55.5	.5
Sandy Clay		55.5	79	23.5
gravel	water	79	80	1
Sandy Clay		80	86	6
gravel	water	86	87	1
Sandy Clay		87	100	13
Soft Sand Stone		100	102	2
Sandy Clay		102	114	12
gravel	water	114	114.5	.5
Clay		114.5	118.5	3.5
gravel		118	119	1
Clay		119	122	3
gravel	water	122	122.5	.5
Clay		122.5	122.5	3.5

8. WELL CONSTRUCTION  
 Diameter 6.8 inches Total depth 126 feet  
 Casing record 127'  
 Weight per foot \_\_\_\_\_ Thickness 1.56  
 Diameter well From To  
10 inches 0 feet 50 feet  
8 inches 50 feet 126 feet  
 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 4'-50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 126 feet  
 Perforations:  
 Type perforation mill  
 Size perforation 8 x 3 - 6 row  
 From 86 feet to 126 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 122 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started February 13 1989  
 Date completed 27 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Nathan R. Maynard Contractor  
 Address P.O. Box 126 Land NV 89317 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0022869  
 Nevada contractor's driller's number issued by the Division of Water Resources 1538  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed Nathan Maynard  
 By driller performing actual drilling on site or contractor  
 Date March 3 1989

BAILER TEST  
 G.P.M. 40 Draw down to 46 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours