WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31306
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5533

1. OWNER CARL COSTANZO
MAILING ADDRESS BOX AAA HCR 31
JEAN, NEV. 89019

ADDRESS AT WELL LOCATION KINGSTON ROAD
NEAR SANDY MILL, SANDY VALLEY, NV.

2. LOCATION SW ¼ NE ¼ Sec. 5 T. 25 N/S R. 57 E CLARK County
PERMIT NO. (Issued by Water Resources) 620-500-007 (Parcel No.) NA (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY LOAM		0	16	16
SANDSTONE		16	47	31
BROWN CLAY		47	52	5
CALICHE	WTR 52	52	54	2
BROWN CLAY		54	64	10
CON'S WHITE CLAY		64	79	15
BROWN CLAY		79	87	8
CALICHE	WTR	87	91	4
BROWN CLAY		91	119	28
CALICHE	WTR	119	125	6

RECEIVED
MAR 21 1989
Div. of Water Resources
Branch Office Las Vegas, Nv

Date started FEB 18, 1989
Date completed FEB 23, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	25	3	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 125 feet
inches
inches
Casing record 8 5/8 STEEL
Weight per foot 12.5 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 125 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4" 5 Rows @ 16" ctr
From 95 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 49 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 66 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.C.B.B. INC. (Contractor)
Address 1701 W. CHSTN BLVD. LAS VEGAS NV. 89102 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spulock (By driller performing actual drilling on site or contractor)
Date March 20 89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627