WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31311
Permit No.
Basin

NOTICE OF INTENT NO. 5783

PRINT OR TYPE ONLY

1. OWNER FRANK A. BROWN
MAILING ADDRESS 2067 LAS VEGAS BLVD. NO. SP. # 42 NO. LAS VEGAS, NV. 89030
ADDRESS AT WELL LOCATION VANDELL EAST OF LESLIE PAHRUMP

2. LOCATION N.W. ¼ S.W. ¼ Sec. 17 T. 20 N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT 404 (Parcel No.) CAL VEGAS RANCHOS, UNIT F (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD BROWN CLAY		1	4	3
GREY CLAY		4	7	3
BROWN CLAY		7	28	21
HARD BROWN CLAY		28	39	11
BROWN CLAY		39	48	9
HARD BROWN CLAY		48	54	6
GREY CLAY		54	75	21
HARD BROWN CLAY		75	79	4
BROWN CLAY		79	91	12
HARD BROWN CLAY		91	102	11
BROWN CLAY		102	127	25
HARD BROWN CLAY		127	131	4
BROWN CLAY		131	140	9

RECEIVED
MAR 24 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-7, 1989
Date completed 3-14, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 140 feet
inches
inches
Casing record 140 FT. 8 5/8 O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation ½" x 6"
From 80 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RONEGOYD PUMP & DRILLING (Contractor)
Address BOX 157 PAHRUMP, NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7479-A
Nevada contractor's driller's number issued by the Division of Water Resources 1424
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1427 - STAN HARDIN
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/15-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627