

Log No. 31316

Permit No. _____

Basins _____

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5779

PRINT OR TYPE ONLY

1. OWNER RUSSELL D. BRUNER ADDRESS AT WELL LOCATION _____

MAILING ADDRESS 7191 FOREST USTA
LAS VEGAS, NV. 89117

2. LOCATION S.E. 1/4 N.W. 1/4 Sec 7 T. 21 N. R. 54 E. N4E County _____

PERMIT NO. LOT 4 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
BROWN CALICHE		1	5	4
GREY CALICHE		5	9	4
BROWN CALICHE		9	26	17
HARD BROWN CALICHE		26	34	8
BROWN CALICHE		34	46	12
HARD BROWN CALICHE		46	64	18
BROWN CLAY		64	70	6
HARD BROWN CALICHE		70	90	20
BROWN CLAY		90	96	6
HARD BROWN CALICHE		96	111	15
GREY CLAY		111	125	14
BROWN CLAY		125	140	15

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 140 feet

Casing record 140' 8 5/8" O.D. STEEL

Weight per foot _____ Thickness 188

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation TORCH CUT

Size perforation 1/2" X 6"

From 80 feet to 140 feet

From _____ feet to _____ feet

RECEIVED
 MAR 8 1989
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 2-14 1989

Date completed 2-17 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 37 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RON FLOYD PUMP & DRILLING Contractor

Address BOX 157 PAHRUMP, NV, 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 7479-A

Nevada contractor's driller's number issued by the Division of Water Resources 11424

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1427-STAN HARDIN

Signed [Signature] By driller performing actual drilling on site or contractor

Date 2-20-89