WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31362
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5620

1. OWNER Matt Harber
MAILING ADDRESS P.O. Box ~~275~~ 27476
Las Vegas, NV 89126

ADDRESS AT WELL LOCATION
6200 Corbett Lane

2. LOCATION NE ¼ SE ¼ Sec. 26 T. 19 ~~S~~ N R. 60 E. Clark County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	20	20
Sand & caliche		20	40	20
Gravel & caliche		40	60	20
Caliche		60	160	100
White clay & gravel		160	200	40
Gravel		200	260	60
Clay & gravel		260	300	40
Some caliche & gravel		300	320	20
Gravel		320	350	30

RECEIVED
MAR 31 1989
Div. of Water Resources
Branch Office - Las Vegas

Date started October 7, 1988
Date completed December 27, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 350 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1 feet	350 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 350 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8x2½" 8 rows
From 230 feet to 330 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 220 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC.
Address 4185 W. Harmon Contractor
Las Vegas, NV 89103 Contractor
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard R. Thompson
By driller performing actual drilling on site or contractor
Date March 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627