WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31397
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9919

1. OWNER Ray Borgman
MAILING ADDRESS 3137 Bedie Rd Gardnerville, Nevada
ADDRESS AT WELL LOCATION 3127 Bedie Spring Valley Ranchaea

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-254-01 (Parcel No.) Spring Valley Ranchos (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/gravel		0	8	8
Compacted Clay very tight & Hard		8	10	2
Cemented pea gravel with clay lenses, hard & tight		10	70	60
Grey Sandstone Medium to hard		70	94	24
Cemented pea gravels with fine sand, fractured with water courses	✓	94	117	23
Sandstone, tight		117	121	4
Total depth ft				

Date started April 17 19
Date completed April 22 89 1958

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
developed & gravel packed with 250 psi air			
Making 15 GPM from 105'			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 11¼ to 50 inches Total depth 121 feet
8½ inches
inches
Casing record Steel 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	121 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 96 feet to 116 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 57 feet below land surface
Flow 15 G.P.M. P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name E H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 83295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quentin R Butts
By driller performing actual drilling on site or contractor
Date April 25, 1989

97: 01 14 AM '89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627