

OFFICE USE ONLY
 Log No. 31402
 Permit No. 49772
 Basin 105-Carson V.
 NOTICE OF INTENT NO. 9905

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Sac. Dist. Church of the Nazarene ADDRESS AT WELL LOCATION Pinenut & Eastvalley Rd.

MAILING ADDRESS P. O. Box 181
Minden, Nv. 89423

2. LOCATION NE 1/4 SE 1/4 Sec 11 T12 N/R 20E E Douglas County

PERMIT NO. 49772 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sagebrush Alluvium		0	1	1
Fine grained sand some clay		1	3	2
Same with abundant cobbles		3	7	4
Sand gravel cobbles		7	90	83
Softer sand gravel	XXX	90	98	8
Hard sand gravel cobbles with an occasional clay bed mostly volcanic origin		98	200	120

Date started 2-23-88, 19.....
 Date completed 3-2-88, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR LIFT	EST. 50 GPM		
		30:00	3-11-88

BAILER TEST

G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 200 feet

Casing record
 Weight per foot 12 Thickness 156

Diameter	From	To
<u>6</u> inches	<u>+2</u> feet	<u>200</u> feet
.....inchesfeetfeet

Surface seal: Yes No Type Cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50' feet to 200' feet

Perforations:
 Type perforation mill cuts
 Size perforation 1/8 X 2 1/2
 From 140' feet to 160' feet
 From 180' feet to 200' feet
 Fromfeet tofeet
 Fromfeet tofeet

9. WATER LEVEL

Static water level 55' feet below land surface
 Flow.....G.P.M.P.S.I.
 Water temperature cold °F Quality UK

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Oasis Drilling Inc. Contractor
 Address P.O. Box 2008, Gardnerville, Nv. Contractor 89410
 Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada contractor's driller's number issued by the Division of Water Resources.....
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Hanz By driller performing actual drilling on site or contractor
 Date March 6, 1988