WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31404
Permit No. 52617
Basin 10-122

NOTICE OF INTENT NO. 12231

1. OWNER CITY OF GABBS
MAILING ADDRESS GABBS, NV 89409

ADDRESS AT WELL LOCATION 4 MILES NORTH OF GABBS ON STATE RTE 23 2500 FT EAST OF ROAD

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 12 N/S R. 36 E. NYE County
PERMIT NO. 152617 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE MATERIAL		0	5	5
SAND & GRAVEL		5	35	30
CLAY		35	45	10
CLAY-SAND-GRAVEL		45	80	35
HARD CLAY		80	82	2
CLAY-SAND-GRAVEL	X	82	94	12
CLAY		94	98	4
CLAY-SAND-GRAVEL	X	98	145	47
CLAY-SAND-LG GRAVEL	X	145	195	50
CLAY		195	210	15
CLAY-SAND	X	210	260	50
CLAY-SAND-GRAVEL	X	260	310	50

STATE ENGINEERS OFFICE
RECEIVED
'89 APR 27 A9:52

Date started MARCH 23, 1989
Date completed APRIL 14, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	450	6'	24 HRS

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 310 feet
..... inches
..... inches
Casing record 8 5/8 X 310
Weight per foot 22.36 Thickness .250

Diameter	From	To
8 5/8 inches	0 feet	310 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 300 feet

Perforations:
Type perforation JOHNSON SCREEN
Size perforation 70 SLOT
From 150 feet to 230 feet
From 280 feet to 300 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 68 °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date APRIL 25, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627