WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31409
Permit No.
Basin 207 - WHITE RIVER V

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 49939

1. OWNER Jim Luce
MAILING ADDRESS Po Box 235 Lund Nv. 89317

ADDRESS AT WELL LOCATION parcel 2 Block 16

2. LOCATION SE ¼ SW ¼ Sec. 21 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. (Issued by Water Resources) Parcel No. Lund ten ACRE plat (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	5	5'
cobbles-gravel		5	7	2'
cobbles cemented		7	15	8'
Sandy clay		15	40	25'
gravel		40	42	2'
Sandy Clay		42	45	3'
gravel		45	47	2'
Sandy Clay		47	51	4'
gravel		51	53	2'
Sandy clay		53	58	5'
gravel		58	60	2'
Sandy clay		60	65	5'
gravel	water	65	68	3'
clay		68	71	3'
gravel	water	71	73	2'
S clay		73	78	5'
gravel	water	78	82	4'
Sandy Clay		82	107	25'
gravel	water	107	110	3'
clay		110	115	5'
gravel		115	116	1'
clay		116	120	4'
gravel	water	120	121	1'
clay		121	126	5'
gravel		126	128	2'
clay		128	130	2'

Date started April 5, 1989
Date completed April 13, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 130 feet
inches
inches
Casing record 131'
Weight per foot Thickness .156

Diameter	From	To
10 inches	0 feet	50 feet
8' inches	50 feet	90 feet
6 inches	90 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete grouted
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 90 feet to 50 feet

Perforations:
Type perforation mill
Size perforation ¼ x 2 6 rows
From 70 feet to 90 feet
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada contractor's driller's number issued by the Division of Water Resources 1538
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orwan Maynard (By driller performing actual drilling on site or contractor)
Date April 22-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627