

OFFICE USE ONLY
Log No. 31426
Permit No. 52506
Basin 10-108 Mason V.

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9678

1. OWNER RALPHINE CARLTON ADDRESS AT WELL LOCATION NE 1/4 NR 31-15N-25E
MAILING ADDRESS 8912 QUAIL HILL WAY M.D.M./FRAN WHEEL PERMIT THE W.Y. CORNER OF
FAZIOAKS, CA, 95628 SEC 30 T 15N 25E MOUNT BURNS N 41 19 33 W
2. LOCATION NE 1/4 NR 31 T 15 S R 25 E 5, 825 FT. FT 1 yard County
PERMIT NO. 52506 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY + SAND		0	10	10
COARSE SAND		10	40	30
BLUE CLAY + COARSE SAND		40	45	5
BLUE CLAY		45	60	15
COARSE SAND	X	60	97	37

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 97 feet
Casing record
Weight per foot _____ Thickness .156
Diameter From To
6 3/8 inches (H) 1 feet 97 feet
Surface seal: Yes No Type GRAUT
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 97 feet
Perforations:
Type perforation SAWED
Size perforation 3/32" x 3" x 6 ROWS
From 77 feet to 97 feet

9. WATER LEVEL
Static water level 7' 10" feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OLDEN BROS. DRILLING Contractor
Address 162 N. BIRCH LN. YUKON TERRAZAS Contractor
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 870 + 630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 870
Signed Billy Bosh By driller performing actual drilling on site or contractor
Date 4-3-89

Date started 3-26 1989
Date completed 3-31 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>60</u>	<u>13' 2"</u>	<u>3</u>

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

STATE ENGINEERS OFFICE
RECEIVED
APR 14 10 54