

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 12477

PRINT OR TYPE ONLY

1. OWNER BRADY BITZ ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 10550 Chesapeak 8115 Mowhawk  
Reno, NV 89506 Reno, NV 89506  
2. LOCATION NE 1/4 NE 1/4 Sec. 17 T. 20N N/S R. 19 E. Washoe County  
Horizon Hills  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay w/gravels		1	45	44
Soft zone (3-4 GPM)	X	45	50	5
NOTE: Above sanitary seal				
Brrown sandy clay with some boulder & gravels		50	154	104
Soft zone (NO H2O)		154	162	8
Brown sandy clay with gravels		162	205	43
Soft zone (NO H2O)		205	208	3
Brown sandy clay with gravels		208	297	89
Soft zone (NO H2O)		297	301	4
Brown sandy clay with gravels		301	387	86
Reddish brown clay		387	397	10
Soft zone (NO H2O)		397	399	2
Reddish brown clay		399	406	7
Brown clay		406	410	4
Soft zone (NO H2O)		410	412	2
Brown clay with gravels		412	465	53
Soft zone (app 3 GPM-4) X		465	466	1
Brown soft KXXX clay		466	483	17
Soft weathered granite		483	500	17
From 476 ft. to 500 ft. backfill.				

8. WELL CONSTRUCTION  
Diameter 6 inches Total depth 476 feet  
Casing record 476' steel casing installed.  
Weight per foot \_\_\_\_\_ Thickness .156  
Diameter 6 5/8 inches From 0 feet To 476 feet  
Surface seal: Yes  No  Type cement  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from 50 feet to 476 feet  
Perforations:  
Type perforation factory sawed slot  
Size perforation 3/32 x 3 x 6 around  
From 411 feet to 431 feet  
From 451 feet to 471 feet

9. WATER LEVEL  
Static water level 138 feet below land surface  
Flow 4 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality clear

Date started 4-17-89 19\_\_\_\_  
Date completed 4-20-89 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling, Inc.  
Address P.O. Box 12370, Reno, NV 89510  
Nevada contractor's license number issued by the State Contractor's Board 22549  
Nevada contractor's driller's number issued by the Division of Water Resources 908  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
Signed [Signature]  
Date April 24, 1989

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours