WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31517
Permit No.
Basin 4-43

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12607

1. OWNER Frank Hooper - U3 RANCH
MAILING ADDRESS PO Box 1133 Elko NV 89801
ADDRESS AT WELL LOCATION old Reynolds Ranch - wells

2. LOCATION SW ¼ NE ¼ Sec. 11 T. 37 N/S R. 61 E. Elko County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	
clay - light tan		4	10	
Large semi-con gravels		10	15	
sand - brown		15	20	
alternating layers clay/sand		20	40	
gravels (some water)		40	45	
lt brown clay		45	50	
" " " & sand		50	55	
alternating layers		60	120	
clay		120	130	
layers clay & gravels		130	150	

RECEIVED
STATE ENGINEERS OFFICE
APR 17 AM 9:51

Date started 3/27, 1989
Date completed 3/27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 145 feet
..... inches
..... inches
Casing record 145' 6x156
Weight per foot ..... Thickness .....

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 145 feet

Perforations:
Type perforation torchcut 3-3" slots perft
Size perforation 4 rows in 20'
From 3 rows 115 feet to 124 feet
From 4 rows 115 feet to 144 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35 ft feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RD Reynolds Drilling (Contractor)
Address PO Box 402 Wells NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 01440
Nevada contractor's driller's number issued by the Division of Water Resources 1390
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585
Signed Russell Boley
By driller performing actual drilling on site or contractor
Date 3/28/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627