WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

AB

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31539
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 12059

1. OWNER Mike Pradere
MAILING ADDRESS Dayton, NEV 89403
LOCATION NW ¼ NE ¼ Sec. 27 T. 17 N S R. 22 E. Lyon County
PERMIT NO. 20 (Issued by Water Resources) 19-204-04 (Parcel No.)
ADDRESS AT WELL LOCATION 92 Wells Fargo Pinenut View Estates
Pinenut View Estates (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 3 | 3 |
| Clay & Sand | | 3 | 15 | 12 |
| Rock | | 15 | 19 | 4 |
| Cemented Gravel | | 19 | 91 | |
| Brick Sand | ✓ | 91 | 95 | 4 |
| Brownies Sand | | 95 | 130 | 35 |
| Brown Clay | | 130 | 137 | 7 |
| Gravel & Sand | ✓ | 137 | 143 | 6 |
| Clay | | 143 | 145 | 2 |

'89 JUN 19 A10:35 RECEIVED STATE ENGINEERS OFFICE

STATE ENGINEERS OFFICE RECEIVED

Date started 6-05, 1989
Date completed 6-20, 1989

'89 APR 20 A9:13 STATE ENGINEERS OFFICE

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 68 | | |

BAILER TEST
G.P.M. 12 to 15 gpm Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8" inches Total depth 145 feet
inches
inches
Casing record 8 5/8
Weight per foot ~~18~~ 18.5 Thickness 188

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 53 feet |
| 8 inches | 53 feet | 145 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Ready Mix
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 32
From 115 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 93' feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W. M. Blain Well Drilling (Contractor)
Address 2537 Larry Cir CC, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10950
Nevada contractor's driller's number issued by the Division of Water Resources 1118
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1118
Signed Wanda M. Blain (By driller performing actual drilling on site or contractor)
Date 3/20/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627