

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2809

PRINT OR TYPE ONLY

1. OWNER Lloyd ~~Thorne~~ Thayne ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 590 E. Regina 7200 block of Rome  
North Las Vegas, NV 89030  
 2. LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 22 T. 19 SR 60 E. Clark County  
 PERMIT NO. 53392 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		150	160	10
White clay & sand		160	200	40
Clay & gravel mix		200	220	20
White clay & sand		220	240	20
White clay & gravel		240	260	20
Clay & gravel		260	280	20
Clay		280	320	40
Clay & saand		320	340	20
White clay & gravel		340	360	20
Clay & gravel stringers		360	380	20
Clay & sand		380	400	20
White clay & grav. mixed		400	420	20
(Top 150' drilled by others)				

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 420 feet

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness .188

Diameter	From	To
<u>6</u> inches	<u>150</u> feet	<u>420</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type \_\_\_\_\_ feet  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Mill slots  
 Size perforation 1/8x2 1/2 6 rows  
 From 340 feet to 420 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
**MAY 10 1989**  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started May 3, 1989  
 Date completed May 8, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMPSON DRILLING CO., INC.  
4185 W. Harmon Contractor  
 Address Las Vegas, NV 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 4286A  
 Nevada contractor's driller's number issued by the Division of Water Resources 290  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or contractor  
 Date May 9, 1989

