

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 12868

1. OWNER Gary Moyle ADDRESS AT WELL LOCATION Not assigned yet
MAILING ADDRESS 1952 Mally Dr
Carson City, Nev. 89706
2. LOCATION NW 1/4 SE 1/4 Sec 29 T 10 N/S R 22 E Douglas County
PERMIT NO. 39-200-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation
Municipal Industrial Test Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MULTI-COLORED ROCKS MIXED W/CLAY</u>		<u>0</u>	<u>140</u>	<u>140</u>
<u>white clay</u>		<u>140</u>	<u>150</u>	<u>10</u>
<u>BROKEN & FRACTURED X MULTI-COLORED ROCK</u>		<u>150</u>	<u>197</u>	<u>47</u>
<u>HARD ROCK</u>	<u>X</u>	<u>197</u>	<u>200</u>	<u>3</u>

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 200 feet

Casing record
Weight per foot 18 Thickness 1.88

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>200</u> feet

Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation FACTORY SLOT
Size perforation 1/8" x 3" 6 Per Foot
From 160 feet to 200 feet

Date started 5-30 1989
Date completed 5-31 1989

9. WATER LEVEL
Static water level 90 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature 58 °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Energy Exploration Drilling Inc Contractor
Address P.O. Box 1538 Minden NV 89423 Contractor
Nevada contractor's license number issued by the State Contractor's Board 21491
Nevada contractor's driller's number issued by the Division of Water Resources 1407
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407
Signed Sam Woods
By driller performing actual drilling on site or contractor
Date 6-1-89

BAILER TEST

G.P.M.	Draw down	feet	hours