WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31607
Permit No.
Basin 10-137-b

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5036

1. OWNER Charlie Wilkerson
MAILING ADDRESS Gardners Round Mountain, Nv.

ADDRESS AT WELL LOCATION

2. LOCATION ¼ ¼ Sec. 29 T. 11 N/S R. 43 E. Nye County
PERMIT NO. (Issued by Water Resources) 2 (Parcel No.) File # 62273 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	
gravel		5	12	
Grey Clay		12	18	
gravel		18	22	
Brn Cly		22	25	
gravel		25	28	
Brn Cly		28	30	
Sd	✓	30	33	
Brn Cly		33	43	
Sd	✓	43	44	
Gry Clay		44	55	
gravel		55	60	
Brn Cly		60	67	
Sd	✓	67	70	
wht Cly		70	80	
Brn Cly		80	86	
Sd	✓	86	93	
Brn Cly		93	100	
gravel	✓	100	135	

Date started 5-7, 1989
Date completed 5-8, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Air Lift		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½/9⅞ inches Total depth 135 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
6 inches	0 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Mill slot
Size perforation 48" x 3"
From 100 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 22 feet below land surface
Flow 100 G.P.M. ..... P.S.I.
Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling Co (Contractor)
Address 4662 Maynard (Contractor) Sparks, Nv.
Nevada contractor's license number issued by the State Contractor's Board 24521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Waytek (By driller performing actual drilling on site or contractor)
Date 5-11-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627