

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 11909

1. OWNER Terry Bunkowski  
Bred Aldridge ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 202 E. Coast St.  
Yerington, Nev. 89497 Domenici Ranch  
Yerington, Nev. 89497  
 2. LOCATION S 1/4 SW 1/4 Sec. 22 T. 13. N 8 R. 25 E County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy loam topsoil</u>	<u>Yes</u>	<u>0</u>	<u>12</u>	<u>12</u>
<u>Sand and gravel</u>	<u>No</u>	<u>12</u>	<u>28</u>	<u>16</u>
<u>Yellow sandy clay</u>		<u>28</u>	<u>36</u>	<u>8</u>
<u>Sand</u>		<u>36</u>	<u>50</u>	<u>14</u>
<u>Gravel and sand with some clay strata</u>	<u>Yes</u>	<u>50</u>	<u>130</u>	<u>80</u>

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 130 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.88

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>130</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 28 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory saw slot  
 Size perforation 3/32" x 3"  
 From 110 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-18-89, 1989  
 Date completed 4-23-89, 1989

7. WELL TEST DATA STATE

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>?</u>	<u>20</u>	<u>0</u>	<u>3</u>
	<u>58: 67 5- NW 68.</u>		

BAILER TEST

G.P.M. 30 + Draw down 1 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 8 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDMLCO, INC.  
 Address Box 92, Smith, Nev. 89430  
 Nevada contractor's license number issued by the State Contractor's Board 24199  
 Nevada contractor's driller's number issued by the Division of Water Resources 24199  
 Nevada driller's license number issued by the Division of Water Resources 718  
 Signed Edmund Miller  
 By driller performing actual drilling on site or contractor  
 Date 5-2-89