WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31634
Permit No. 53063
Basin 103 - DAYTON V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12750

1. OWNER MAX & SARA NORTON
MAILING ADDRESS GARDNERVILLE, NEVADA
ADDRESS AT WELL LOCATION FRONTS STRTE 341 MOUNDHOUSE, NEVADA

2. LOCATION NW ¼ SE ¼ Sec. 29 T. 16 N S R. 21 E. LYON County
PERMIT NO. W-301 (Issued by Water Resources) 16-194-09 (Parcel No.) NONE (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other TEST ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR + MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN WITH CLAY		0	5	5
BROWN CLAY WITH GRAVELS		5	80	75
LOOSE GRAVELS W/ SAND	✓	80	110	30
BROKEN LAVA TYPE ROCK	✓	110	185	65
BROWN CLAY, TIGHT, W/SAND		165	180	15
NOTE: 10 FEET OF PEAGRAEL IN BOTTOM TO FILTER FINE SAND				
T.D. 180 FEET				

STATE ENGINEERS OFFICE
'89 MAY 8 PM 1:00

Date started May 5, 1989
Date completed May 10, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed, Cleaned and Gravel Packed Using 250 psi 460 CFM Air Blew 80 GPM FROM 100 FEET FOR 2 HOURS TO Clean			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4" inches Total depth 180 feet
..... inches
..... inches
Casing record 8 5/8" STEEL
Weight per foot 28.0 Thickness .188

Diameter	From	To
8 5/8 inches	+2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete Cell Mix
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 180 feet

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3/32" X 3"
From 80 feet to 100 feet
From 140 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46 feet below land surface
Flow 85+ G.P.M. ..... P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address CARSON CITY, NEVADA (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed ..... By driller performing actual drilling on site or contractor
Date May 10, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627