

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9910

PRINT OR TYPE ONLY

1. OWNER Young Builders, Inc. ADDRESS AT WELL LOCATION 30 Darilyn Lane Carson City, Nevada
 MAILING ADDRESS P.O. Box 18196 Reno, Nevada 89511

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T. 17 N. R. 20 E. Washoe County
 PERMIT NO. 050-060-10 Issued by Water Resources Parcel No. _____ Subdivision Name New Washoe City

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other RMW

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden & blow sand</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Fine sand w/ thin clay seams</u>	<input checked="" type="checkbox"/>	<u>6</u>	<u>30</u>	<u>24</u>
<u>Fine to medium sand w/ water & fine silt</u>	<input checked="" type="checkbox"/>	<u>30</u>	<u>107</u>	<u>77</u>
<u>Course sand with silt & clay layers</u>	<input checked="" type="checkbox"/>	<u>107</u>	<u>140</u>	<u>33</u>
T.D. 140 Feet				

Note: 10' feet blank at bottom filled with gravel to stop silt.

8. WELL CONSTRUCTION

Diameter 12 1/8 to 140 inches Total depth 140 feet

Casing record 6 5/8" Steel

Weight per foot 11.7 Thickness .156

Diameter	From	To
<u>6 5/8" inches</u>	<u>72</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete

Depth of seal 60 feet

Gravel packed: Yes No

Gravel packed from 60 feet to 140 feet

Perforations: Type perforation Factory Mill slot

Size perforation 3/32 x 3/64

From 110 feet to 130 feet

From _____ feet to _____ feet

Date started May 25 1989
 Date completed May 26 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew 25-30 GPM from 80' developed & gravel packed with bit</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 12 feet below land surface

Flow 25+ G.P.M. _____ P.S.I.

Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AJ H Pump Co Contractor

Address Carson City, NV 89201 Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450

Signed Quinton Smith By driller performing actual drilling on site or contractor

Date May 30, 1989