

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9220

PRINT OR TYPE ONLY

1. OWNER BOB HAWKE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 715 Ruby Ave. 690 Dog Valley Road
Reno, NV 89503 Verdi, NV 89439
 2. LOCATION NW 1/4 SE 1/4 Sec 7 T 19N N/S R. 18 E Washoe County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay w/some bolder & gravels		1	17	16
Brown broken volcanic rock		17	30	13
Brown volcanic rock		30	61	31
Gray volcanic rock		61	130	69
Fracture rock (NO H2O)		130	134	4
Gray volcanic rock		134	180	46
Fracture (app. 3 GPM)	X	180	183	3
Gray volcanic rock		183	205	22
Fracture (app. 3 GPM)	X	205	207	2
Gray volcanic rock		207	230	23
Fracture rock		230	253	23
Gray volcanic rock		253	288	35
Fracture	X	288	289	1
Gray hard volcanic rock		289	300	11

89 MAY 22 AIC:11
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 300 feet
 _____ inches
 _____ inches
 Casing record 300' steel casing installed.
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal _____ 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 300 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 235 feet to 255 feet
 From 275 feet to 295 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 5-16-89, 19____
 Date completed 5-17-89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 47 feet below land surface
 Flow 24 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, INC. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date May 18, 1989