WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31673
Permit No. 53313
Basin 6-8C

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10854

1. OWNER RENO SPARKS INDIAN COLONY
MAILING ADDRESS 15A RESEEVATION ROAD
RENO, NV 89502
ADDRESS AT WELL LOCATION HUNGRY VALLEY
washoe county

2. LOCATION ~~SE~~ NE ¼ NW ¼ Sec. 4 T. 21 N/S R. 20 E. WASHOE County
PERMIT NO. W-278 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	8	8
HARD CLAY		8	17	9
DARK CLAY		17	81	64
HARD CLAY		81	84	3
DARK GRN CLAY		84	211	127
DRK GRN CLY & ROCK	X	211	375	164
HARD STRINGER	X	375	380	5
CLAY & GRAVEL	X	380	540	160
SAND & GRAVEL	X	540	595	55
CLAY		595	610	15
ROCK	X	610	620	10
CLAY & SAND	X	620	670	50
CLAY		670		

Date started FEBRUARY 14, 19 89
Date completed APRIL 28, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	200	330'	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 16 inches Total depth 670 feet
..... inches
..... inches
Casing record 10 3/4 X 420 6 5/8 X 240
Weight per foot 28.04 Thickness .250

Diameter	From	To
10 3/4 inches	0 feet	420 feet
6 5/8 inches	420 feet	660 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 65 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 400 feet to 660 feet

Perforations:
Type perforation JOHNSON SS SCREEN
Size perforation 70/1000
From 425 feet to 465 feet
From 525 feet to 565 feet
From 605 feet to 655 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level FLOWING WELL feet below land surface
Flow 13GPM G.P.M. ..... P.S.I.
Water temperature 70 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date MAY 15, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627