

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY 3/1/89

NOTICE OF INTENT NO. 6321

1. OWNER Bret VanHorn ADDRESS AT WELL LOCATION
MAILING ADDRESS 1425 Dodson Wy. 1210 Goldstone Rd.
Sparks, NV 89431 Sparks, NV 89431
2. LOCATION NW 1/4 SE 1/4 Sec. 24 T. 22 N. R. 19 E. Washoe County
PERMIT NO. N/A Parcel No. 07935206 Subdivision Name Red Rock Estates #418
Issued by Water Resources

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG & Clay		0	18	18
Brown Siltstone w/-				
Sand stringers		18	143	125
Fine Gray Sand		143	156	13
Brown Sandy Clay		156	167	11
Gray Clay		167	213	46
Fine Brown Sandstone				
w/DG		213	225	12
Gray Clay W/Sand				
Stringers	xx	225	400	175

89 2-10-89

STILL

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 400 feet
Casing record 6 5/8" Steel
Weight per foot _____ Thickness .156
Diameter From To
6 inches -1 feet 400 feet
_____ inches _____ feet _____ feet
Surface seal: Yes No Type concrete
Depth of seal 51 feet
Gravel packed: Yes No
Gravel packed from 51 feet to 400 feet
Perforations:
Type perforation Torch Cut
Size perforation 1/8" x 3"-12"
From 280 feet to 300 feet
From 220 feet to 240 feet
From 300 feet to 400 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 5-25-89, 19_____
Date completed 5-28-89, 19_____

9. WATER LEVEL
Static water level 125 feet below land surface
Flow none G.P.M. none P.S.I. _____
Water temperature COOL °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & M Drilling
Address Winnemucca NV
Nevada contractor's license number issued by the State Contractor's Board 0020417-C23
Nevada contractor's driller's number issued by the Division of Water Resources _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 5-28-89

air
BANKER TEST
G.P.M. 40+ Draw down 380 feet 2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours