

OFFICE USE ONLY  
Log No. 31712  
Permit No. 51966  
Basin 03-040 Salton Fall Crater Area

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9058

1. OWNER V-3 II RANCH ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS JACK POT NEVADA

2. LOCATION NW 1/4 NW 1/4 Sec. 2 T. 47 N. R. 64 E. ELKO County  
PERMIT NO. 51966 Issued by Water Resources Parcel No. Lot 8 Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock  Other

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	2	
BROWN ROCK		2	16	
Black Sand Rock		16	24	
Red + Brown Rhyolite (BROKEN)		24	118	
Red Rhyolite (BROKEN)		118	125	
Red + Brown Rhyolite (BROKEN)		125	192	
Red Rhyolite (HARD)		192	305	
Black Rock (BROKEN)		305	317	
Brown Rhyolite (BROKEN)		317	321	
Red + BROWN CLAYSTONE		321	330	
BROWN SAND ROCK		330	342	
Black Rhyolite (BROKEN)		342	345	
Red Rhyolite (BROKEN)		345	365	
Red Rhyolite (HARD)		365	505	
Red Rhyolite (BROKEN) YES		505	520	
Red Rhyolite (HARD)		520	560	
Red Rhyolite (BROKEN) YES		560	562	
Red Rhyolite (HARD)		562	569	

8. WELL CONSTRUCTION  
Diameter 14 inches Total depth 569 feet  
10 inches  
8 inches

Casing record  
Weight per foot \_\_\_\_\_ Thickness .188

Diameter	From	To
<u>10</u> inches	<u>+1</u> feet	<u>55</u> feet
<u>8</u> inches	<u>+2</u> feet	<u>129</u> feet
<u>6</u> inches	<u>-10</u> feet	<u>569</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type CEMENT GROUT  
Depth of seal 55 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
Type perforation TORCH  
Size perforation 1/8 x 6  
From 509 feet to 569 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 499 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 61 °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name GASTRIN + YANKE Well Drilling Contractor  
Address Mc 38 Box 10 Donnelly, Idaho 83615 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0022322  
Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1543  
Signed Robert W. Steinhilber  
By driller performing actual drilling on site or contractor  
Date 5-2-89

Date started 3-11 1989  
Date completed 5-1 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. 35 AIR TEST Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours