31780

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31780
Permit No.
Basin 6-87 Truckee Meadows

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9226

1. OWNER HERB EIKELBERGER
MAILING ADDRESS 347 S Rock Blvd.
Sparks, NV 89431

ADDRESS AT WELL LOCATION
6295 Mt Rose Hwy
Reno, NV 89511

2. LOCATION SE ¼ SE ¼ Sec. 27 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Calahan Ranch area (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Bolders & gravels with brown clay		3	81	78
Brown sandy clay		81	141	60
Boulder & gravels with brown clay		141	165	24
Soft zone (NO WATER)		165	167	2
Boulders & gravels with brown clay		167	206	39
Volcanic bolder		206	215	9
Bolders & gravel with brown clay		215	240	25
Brown volcanic rock		240	308	68
Fracture (NO WATER)		308	309	1
Brown volcanic rock		309	315	6
Fracture (NO WATER)		315	316	1
Brown volcanic rock		316	369	53
Fracture (NO WATER)		369	370	1
Brown volcanic rock		370	432	62
Fracture	X	432	434	2
Brown volcanic rock		434	450	16

Date started 5-23-89, 19
Date completed 5-26-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 450 feet
inches
inches
Casing record 450' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	450 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 450 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 425 feet to 445 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 405 feet below land surface
Flow 7 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, REno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627