

OFFICE USE ONLY
 Log No. 31783
 Permit No. _____
 Basin G-27

plugged under NDI 61162

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12631

PRINT OR TYPE ONLY

1. OWNER Beverly Tielens ADDRESS AT WELL LOCATION 25 Bargary
 MAILING ADDRESS 25 Bargary 25 Bargary
Reno, Nv 89511 Parcel E of Map 1332
 2. LOCATION SW 1/4 SE 1/4 Sec. 30 T 18 N 20 E Washoe County
 PERMIT NO. 45-630-08 White Creek Enterprises Lot # 8
 Issued by Water Resources 49-940-08 144-231-02 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Grandirite [soft]		2	30	28
Volcanic rock [Broken]		30	112	82
Volcanic rock		112	320	208
Broken volcanic rock		320	350	30
Medium hard volcanic rock		350	457	107
Volcanic gravels		457	505	48
D.G. [Brown] & grandirite		505	585	80
Granadirite		585	597	12
Granadirite with black rock		597	631	34
D.G. brown		631	640	9
T.D. 640 feet				

8. 10"- 57' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 640 feet
6 inches
6 inches
 Casing record 6 5/8 inch & 5 inch
 Weight per foot 10.78 & 6.94 Thickness .156 & .134

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>555</u> feet
<u>5</u> inches	<u>540</u> feet	<u>640</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type well grout
 Depth of seal 59 feet
 Gravel packed: Yes No
 Gravel packed from 59 feet to 555 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 515 feet to 535 feet
 From 600 feet to 620 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 5/23/89, 19____
 Date completed 6/13/89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>blew with air to clean</u>	<u>and develop.</u>		
<u>MIN 20</u>	<u>68.</u>		

9. WATER LEVEL
 Static water level 220 feet below land surface
 Flow 12 G.P.M. P.S.I.
 Water temperature warm °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 5/13/89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours