WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31789
Permit No. 49011
Basin 6-9C

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5025

1. OWNER Bill Stremmel
MAILING ADDRESS P.O. Box 160
Verdi, Nv.

ADDRESS AT WELL LOCATION 2130 Chipmonk

2. LOCATION SW ¼ NW ¼ Sec. 19 T. 19 N/S R. 18 E Washoe County

PERMIT NO. 49011 (Issued by Water Resources) | Lot 10 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	5	
Boulders clay Matrix		5	45	
green gray Clay		45	495	
Wood Chips - DK Brn	✓	495	520	
green Clay		520	536	
S.S.		536	537	
green Clay		537	540	
S.S.		540	541	
gray Clay		541	556	
Brn Clay + wood chips	✓	556	578	
Blue clay		578	582	
SS - Blue/Brn Porous	✓	582	596	
Lt gray Clay		596	606	
SS (Drlg Break)	✓	606	608	
gray Clay		608	612	
SS Drlg Break	✓	612	614	
gray clay		614	618	
SS		618	619	
gray Clay		619	638	
gray /Blue/green clay		638	676	
SS stringers/clay		676	685	
DK Brn clay + wood Chips	✓	685	687	
Brn Clay - Shale		687	690	
SS		690	692	
Brn clay		692	700	

Date started 5-15, 1989
Date completed 6-1, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	52.64	71	68
	Air Lift		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 700 feet
Casing record
Weight per foot 73.38 Thickness .250

Diameter	From	To
20 inches	0 feet	10 feet
12 inches	0 feet	700 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 380 feet to 700 feet

Perforations:
Type perforation Double Port Milled
Size perforation 1/8" X 3"
From 480 feet to 540 feet
From 580 feet to 620 feet
From 680 feet to 700 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 290 G.P.M. ..... P.S.I.
Water temperature C ° F. Quality ?

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co (Contractor)
Address 4662 Maynard Way Sparks, Nv. (Contractor)
Nevada contractor's license number 24521
Nevada contractor's drillers number 1374
Nevada driller's license number 1442 (Actual Driller)
Signed Les Woytek (Contractor)
Date 5-24-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434