

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10215

PRINT OR TYPE ONLY

1. OWNER RENO-SPARKS CONVENTION & VISITORS AUTHORITY ADDRESS AT WELL LOCATION SOUTHEAST CORNER @ FAIRGROUNDS
MAILING ADDRESS P. O. BOX 837 NORTHGATE & WILDCREEK GOLF COURSES
RENO, NEVADA 89504 County WASHOE

2. LOCATION NE 1/4 SW 1/4 Sec 1 T 19 N R 19 E

PERMIT NO. WALVER W-302 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE Site #3
Domestic Irrigation Test
Municipal Industrial Stock Other

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt, sand, gravel		0	20	20
large cobblestones		20	40	20
clay, sand, gravel		40	80	40
large cobblestones with garvel & sand		80	100	20
clay, gravel, sand, silt		100	240	140
black rock with small fractures filled with clay		240	461	221
ABANDONMENT: Pipe placed to bottom of the 461 foot exploration borehole and five cubic yards of neat cement pumped from full depth to ground surface.				
Geophysical Well Log: <u>Welenco</u>				

8. WELL CONSTRUCTION

Diameter 7-7/8 inches Total depth 461 feet

Casing record NOT CASIED

Weight per foot _____ Thickness _____

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement

Depth of seal SURFACE TO 461 feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation _____

Size perforation _____

From _____ feet to _____ feet

Date started JUNE 13, 1989

Date completed JUNE 16, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>2200</u>	<u>1.2</u>	<u>1.5</u>	
<u>2200</u>	<u>1.2</u>	<u>1.5</u>	
<u>2200</u>	<u>1.2</u>	<u>1.5</u>	

BAHER TEST

G.P.M. 68 Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level _____ feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SARGENT IRRIGATION COMPANY Contractor

Address 9955 N. VIRGINIA STREET RENO, NV 89506 Contractor

Nevada contractor's license number issued by the State Contractor's Board 21246

Nevada contractor's driller's number issued by the Division of Water Resources 1391

Nevada driller's license number issued by the Division of Water Resources 1540 the on-site driller

Signed [Signature] By driller performing actual drilling on site or contractor

Date JUNE 21, 1989