WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31811
Permit No.
Basin 7-926

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12878

1. OWNER: SPENCE BITZ REALTY & CONSTRUCTION
MAILING ADDRESS: 575 Mill Street, Reno, Nevada 89502
ADDRESS AT WELL LOCATION: 11595 Tupelo, Reno, Nevada 89506

2. LOCATION: SE ¼ NW ¼ Sec. 22 T. 21N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name: Lemmon Valley

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rop soil		0	1	1
Brown clay		1	31	30
Soft zone, brown sand		31	38	7
Brown saandy clay		38	91	53
Soft zone		91	101	10
Brown clay		101	126	25
Soft zone with brown clau streaks	X	126	148	22
Brown clay		148	151	3
Soft zone	X	151	161	10
Brown clay		161	167	6

JUN 26 '89 AM 1 49 STATE ENGINEER'S OFFICE

Date started 6-19-89, 19
Date completed 6-20-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 167 feet
inches
inches
Casing record 167' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	167 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 167 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 131 feet to 161 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow 16 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Wayne Drilling, Inc.
Address (Contractor) P.O. Box 12370, Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date June 22, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627