WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31823
Permit No. 21839
Basin 10-153

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8243

1. OWNER MAX ALLEN
MAILING ADDRESS BOX 117 CANYON, TEXAS
ADDRESS AT WELL LOCATION EUREKA NEVADA

2. LOCATION SW ¼ SW ¼ Sec. 16 T. 21 N R. 53 E EUREKA County
PERMIT NO. 21839 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ ~~Recondition~~ ☐
Deepen ☐ ~~Other~~ REDRILL ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ REVERSE

6. S and G. LITHOLOGIC LOG Sand and Gravel

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	3
S and G.		3	20	17
CLAY		20	31	11
S & G.		31	40	9
CLAY		40	53	13
S & G.		53	75	22
CLAY		75	80	5
S & G.		80	91	11
CLAY		91	105	14
S & G		105	138	33
CLAY		138	142	4
S & G	90	142	232	90
CLAY		232	238	6
S & G	5	238	243	5
CLAY		243	248	5
CEMTED S&G	5	248	253	5
Replacement of Log # 5550				
[redacted]				
	100			

Date started 10-24-88, 19
Date completed 4-30-89, 19

STATE ENGINEERS OFFICE
RECEIVED

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	1250	20 FEET	12

LS-GW 8-NOV 68

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 27 inches Total depth 253 feet
Casing record ROSCO MOSS
Weight per foot ..... Thickness 250

Diameter	From	To
16" inches	0 feet	253 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 253 feet

Perforations:
Type perforation EXTRUDED
Size perforation 1/8" ROSCO MOSS
From 147 feet to 253 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 108 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALT PLASKETT (Contractor)
Address BOX 10 EUREKA, NEV (Contractor)
Nevada contractor's license number 11882
Nevada contractor's drillers number .....
Nevada driller's license number 635 (Actual Driller)
Signed James E. Groth ~~Contractor~~ DRILLER
Date 4-30-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434