

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10970

1. OWNER Frontier Estates ADDRESS AT WELL LOCATION Hill top area  
 MAILING ADDRESS P.O. Box 1208  
Yreka, California 96097

2. LOCATION 1/4 S. 1/2 1/4 Sec 12 T. 31 N. N/S R. 45 E.E Lander County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. Block B Lot #2 Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil brown		0	2	2
Clay brown		2	10	8
Gravel brown		10	16	6
Sandy clay brown		16	77	61
Gravel brown		77	83	6
Gravelley clay brown		83	109	26
Clay brown W/strips of sand & gravel	16	109	125	16

8. WELL CONSTRUCTION

Diameter 6" inches Total depth 125' feet

Casing record \_\_\_\_\_ inches \_\_\_\_\_ inches

Weight per foot 14 lbs. Thickness .188

Diameter	From	To
<u>6"</u> inches	<u>0'</u> feet	<u>125'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement

Depth of seal 50' feet

Gravel packed: Yes  No

Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:

Type perforation touch

Size perforation 1/8" by 5"

From 102' feet to 125' feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started June 16, 19 89  
 Date completed June 19, 19 89

9. WATER LEVEL

Static water level 12' feet below land surface

Flow good G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_

Water temperature 54 °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T. & R. Drilling Contractor

Address P.O. Box 1982 Wmca., Nv. 98445 Contractor

Nevada contractor's license number issued by the State Contractor's Board 017721

Nevada contractor's driller's number issued by the Division of Water Resources 1190

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190

Signed Thomas Stee  
 By driller performing actual drilling on site or contractor

Date June 25, 1989

BAILER TEST

G.P.M. 20 Draw down 49 feet 3 hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours