WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31881
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12763

1. OWNER Ralph Parish
MAILING ADDRESS P.O. Box 1412 Gardnerville, Nevada
ADDRESS AT WELL LOCATION 551 Lee Allen Drive Gardnerville, Nevada
2. LOCATION SW ¼ SW ¼ Sec. 25 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 19-410-01 | Subdivision Name Day Canyon Estates

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over Burden & boulders		0	7	7
Gravels, Sand & large Boulders		7	84	77
Medium Sized Cobbles with Sand & Gravels	✓	84	120	36
T.D. 120 Feet				

Date started 6/28, 19 89
Date completed 6/30, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with Clean water to remove drill mud (Grave) Pack, Blew with air for 3 hours to finish develop from 80' Blew 21 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 12" 60 ft inches, 9 3/4 inches, inches Total depth 120 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation Factory Mill
Size perforation 3/32" x 3"
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 26 feet below land surface
Flow 26-28 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23495
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 472
Signed Clinton Barth (By driller performing actual drilling on site or contractor)
Date June 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627