WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31882
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12758

1. OWNER Grant Loefflen
MAILING ADDRESS Box 211
Genoa, Nevada 89411

ADDRESS AT WELL LOCATION 413 Gillian Court
Gardnerville, NV

2. LOCATION NW ¼ NW ¼ Sec. 29 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-280-23 (Parcel No.) Theresa Development (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ granite boulders		0	8	8
Granite boulders w/ Loose D.G. Weathered, Medium to hard		8	89	81
Granodiorite, fractured, hard to Medium hard		89	114	33
Fractured granodiorite with small amounts of H2O Major water @ 132-135'	✓	114	140	26

Date started 7/10, 1989
Date completed 7/13, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with air for 3 hrs to remove mud & gravel pack			
Blowing 30 GPM from 135'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 17" to 50' inches Total depth 140 feet
9 3/4 inches
inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 62 feet below land surface
Flow 30 G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/13/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627