WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31885
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12753

1. OWNER Robert Laferty
MAILING ADDRESS Minden, Nevada
ADDRESS AT WELL LOCATION 2035 Pinto Lane Gardnerville, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. 29-470-18 (Issued by Water Resources; Parcel No.) Rheustrau Flats (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ Cobbles, dark brown Clay		0	7	7
Cemented Gravels hard w/ dark to light Clay		7	167	160
Gravel, Course to Semi-fine		167	187	20
Hard, firm Clay with fine Sand		187	189	2
Gravels, Medium to Course w/ Sand	✓	189	220	31
Total depth - 220 Feet				

Date started June 22, 1989
Date completed June 27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & gravel packed well with 250 psi 450 CFM air Blew 20-22 GPM for 3 Hours from 200 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 12" to 60' inches Total depth 220 feet
10 3/4 inches
..... inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 220 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3/32" x 3"
From 180 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 182 feet below land surface
Flow 20-22 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Winston Butts (By driller performing actual drilling on site or contractor)
Date June 27, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627