WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31892
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5233

1. OWNER Jack Fuerschler
MAILING ADDRESS 2663 Snyder Ave
Carson City, Nev.

ADDRESS AT WELL LOCATION Tritia Flat

2. LOCATION NW ¼ NE ¼ Sec. 2 T. 14 N/S R. 20 E. Carson County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam Fill		0	10	
Boulders		10	16	
granite Boulders		16	40	
gravel	—	40	60	
Brn Clay		60	64	
gravel	—	64	80	
gravel - Boulders		80	90	
gravel	—	90	143	
Brn Clay		143	145	

8. WELL CONSTRUCTION
Diameter hole 11½ inches Total depth 145 feet
Casing record
Weight per foot Thickness .08

Diameter	From	To
6 inches	0 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Mill slot
Size perforation ⅛" X 3"
From 105 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 43 feet below land surface
Flow 200 + G.P.M. P.S.I.
Water temperature C ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weyth Drilling Co (Contractor)
Address 4662 Maynard Sparks Nev (Contractor)
Nevada contractor's license number CC 24521
Nevada contractor's drillers number 1374
Nevada driller's license number 1442 (Actual Driller)
Signed Les Weyth (Contractor)
Date 7-7-89

Date started 7-3, 1989
Date completed 7-5, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Air.		
	Lift		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434