WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 31874
Permit No.
Basin 8-102

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Marguerite Blachowiak ADDRESS 1711 E. 9Th ST. Silver Springs Nv. 89429
17-301-01 Parcel 60
2. LOCATION SW ¼ S.E ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Brown Sand		0	40	40
Fine To corse gray sand	X	40	60	20
Fine Brown sand	X	60	80	20
Fine To corse Brown sand	X	80	140	60

'89 JUL 10 A10:47
STATE ENGINEER'S OFFICE

Date started 7-5, 1989
Date completed 7-5, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 8 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 140 feet
Casing record 6 5/8 O.D.
Weight per foot Thickness 156

Diameter	From	To
6 5/8 inches	+1 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Mill
Size perforation 5 X 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36 Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE Drilling & Dev
Address P.O. Box 668 Silver Springs Nv. 89429
Nevada contractor's license number 14299
Nevada driller's license number 726
Signed [illegible]
Date 7-6-89

USE ADDITIONAL SHEETS IF NECESSARY

5471