

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11905

1. OWNER Mr. Tom Terry ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 4120 Fynhorne Circle 2980 Pine Valley Road  
San Diego, Cal. 92130 Gardnerville, NV  
2. LOCATION SW 1/4 NE 1/4 Sec 35 T 11 N/R 21 E Douglas County  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock  Other   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alternat yellow rock and dirt with some yellow clay strata</u>	<u>ABC</u>	<u>0</u>	<u>110</u>	<u>110</u>
<u>Solid rock strata</u>	<u>Yes</u>		<u>110</u>	<u>200</u>

AUG 15 10:48 AM '89  
RECEIVED  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Diameter 8 inches Total depth 200 feet  
6 5/8 inches  
Casing record \_\_\_\_\_  
Weight per foot \_\_\_\_\_ Thickness 188  
Diameter From To  
8 inches 0 feet 110 feet  
6 5/8 inches 110 feet 200 feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 52 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Perforations:  
Type perforation Saw slot  
Size perforation 3/32" x 3"  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 110 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality Good

Date started 7-28-1989  
Date completed 8-2-1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. 15 Draw down 20 feet 5 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EMILCO Contractor  
Address Box 92 Smith, NV 89432 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 24149  
Nevada contractor's driller's number issued by the Division of Water Resources 24149  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
Signed Edmund Miller  
By driller performing actual drilling on site or contractor  
Date 8-10-89